



LEGEND	
	SUBSTATION FENCE
	DISCONNECT SWITCH OPERATOR
DESIGN CRITERIA	
115kV CLEARANCE (650kV BIL):	MIN Ø-G = 42"
LIVE PARTS:	MIN Ø-Ø (METAL TO METAL) = 53"
34.5kV CLEARANCE (200kV BIL):	MIN Ø-G = 13"
LIVE PARTS:	MIN Ø-Ø (METAL TO METAL) = 18"

NO	DATE	REVISION	BY	CHK'D	APP'D

**PRELIMINARY
DRAWING
NOT FOR
CONSTRUCTION**

COPENHAGEN WIND FARM

LEWIS COUNTY, NEW YORK

TYPICAL 115/34.5kV COLLECTOR SUBSTATION GENERAL ARRANGEMENT PLAN VIEW	
DRAWN DATE	SCALE
5/3/22 = 1'-0"	
DRAWING NUMBER	REV
101-01	A

CONFIDENTIALITY STATEMENT: THE ABOVE DRAWINGS, CALCULATIONS, IDEAS, DESIGNS AND ARRANGEMENTS REPRESENTED THEREBY ARE AND SHALL REMAIN THE PROPERTY OF COPENHAGEN WIND FARM, LLC AND NO PART THERE OF SHALL BE COPIED, DISCLOSED TO OTHERS, OR USED IN CONNECTION WITH ANY WORK OR PROJECT OTHER THAN THE SPECIFIC PROJECT FOR WHICH THEY HAVE BEEN PREPARED AND DEVELOPED WITHOUT THE EXPRESSED WRITTEN CONSENT OF COPENHAGEN WIND FARM, LLC. VISUAL CONTACT WITH THESE DRAWINGS OR SPECIFICATIONS SHALL CONSTITUTE CONCLUSIVE EVIDENCE OF ACCEPTANCE OF THESE RESTRICTIONS.